Data in Brief 13 (2017) 248-252

Contents lists available at ScienceDirect

Data in Brief

journal homepage: www.elsevier.com/locate/dib



Data Article

Data on records of indoor temperature and relative humidity in a University building



O. Irulegi^{a,b,*}, A. Serra^b, R. Hernández^a

 ^a Quality of Life in Architecture and Urbanism Group, University of the Basque Country UPV/EHU, Department of Architecture, Plaza Oñate 2, 20018 San Sebastian, Spain
^b South Studio, Adarra 14, 20160 Lasarte-Oria, Spain

ARTICLE INFO

Article history: Received 24 March 2017 Received in revised form 4 May 2017 Accepted 13 May 2017 Available online 18 May 2017

Keywords: Indoor environment Field measurements Educational buildings Building retrofitting Net zero energy buildings

ABSTRACT

Good indoor comfort and air quality are essential for correct educational development. Most reports in this field focus on primary and secondary school buildings, with numerous projects conducted in the Mediterranean Zone. However, little has been done in the context of university buildings. Data on indoor temperature and relative humidity data acquired trough field surveys of a seminar room located in the Architecture Faculty in San Sebastian (Spain) is provided in this paper. The seminar room was monitored during a typical spring week. The data presented in the article are related to the research article entitled Retrofit strategies towards Net Zero Energy Educational Buildings: a case study at the University of the Basque Country (Ref. 0378–7788).

© 2017 The Authors. Published by Elsevier Inc. This is an open access article under the CC BY license (http://creativecommons.org/licenses/by/4.0/).

Specifications Table

| Subject area More specific | Construction & Building technology Building Retrofitting Strategies towards Net Zero Energy Educational Buildings |
|-------------------------------|--|
| subject area | Durang herojiting brategies towards her zero zhengy zadeatonat Danango |
| Type of data | Table, text file |

DOI of original article: http://dx.doi.org/10.1016/j.enbuild.2017.03.030

E-mail address: o.irulegi@ehu.eus (O. Irulegi). *URLS*: https://www.south-studio.com (O. Irulegi), https://www.south-studio.com (A. Serra).

http://dx.doi.org/10.1016/j.dib.2017.05.029

2352-3409/© 2017 The Authors. Published by Elsevier Inc. This is an open access article under the CC BY license (http://creativecommons.org/licenses/by/4.0/).

^{*} Corresponding author.

| How data was acquired | Indoor temperature and Relative Humidity data were acquired trough field surveys by a wireless (SMD SHT 11) and internet-connected technology IoT gateway C4EBOX. Outdoor environmental data were acquired from the Avenida de Tolosa Weather Station of the Basque Government that is located close to the faculty building [2] |
|-----------------------------|--|
| Data format | Raw, filtered and analyzed |
| Experimental factors | |
| Experimental features | A seminar room at the Architecture Faculty was monitored during a typical spring week: from 25th April to 1st May 2016. This paper presents in detail data recorded on 26th April and 28th April where maximum and minimum values were registered |
| Data source location | San Sebastian (Spain) 43°31N, 2°01W |
| Data accessibility | Data is within this article, only outdoor environmental data were acquired from the Avenida de Tolosa Weather Station of the Basque Government that is located close to the Architecture Faculty in San Sebastian [2]: http://www.ingurumena. ejgv.euskadi.eus/r49-3614/es/aa17aCalidadAireWar/datohorario/con taminante?locale=es |
| Related research article | Irulegi O, Ruiz-Pardo A, Serra A, Salmerón JM, Vega R. Retrofit strategies towards Net Zero Energy Educational Buildings: A case study at the University of the Basque Country. Energy and Buildings 2017 144: 387–400. (DOI: http://dx.doi. org/10.1016/j.enbuild.2017.03.030) [1] |

Value of the data

- The data provided in this paper might provide researchers valuable information about real indoor environmental parameters of existing educational buildings.
- The dataset in this paper might help researchers to evaluate real user comfort preferences in higher educational buildings located in a temperate climate or similar cultural context.
- The data might help researcher to evaluate the building energy performance of buildings located in a temperate climate or similar cultural context to define retrofit strategies.
- The data provided might help researcher to consider user preferences as an energy saving opportunity.

1. Data

The data collected in the article are related to the research article entitled *Retrofit strategies towards Net Zero Energy Educational Buildings: a case study at the University of the Basque Country (Ref.* 0378–7788) [1]. The dataset presented in this paper correspond to the indoor temperature and relative humidity of a seminar room located on the second floor of the Architecture Faculty in San Sebastian (Spain). The inputs correspond to a typical spring week: from 25th April to 1st May 2016, being the heating system off. In the following Tables 1 and 2 data for the day with the maximum values (26th April) and the day with the minimum values (28th April) are presented.

The average outdoor temperature on 26th April was 11.8 °C and the average relative humidity 73.3% (Table 1). The maximum outdoor temperature was 14.2 °C and was registered at 14:00. The minimum outdoor temperature was 9.4 °C and was registered at 06:00. The average indoor temperature on 26th April was 22.8 °C and the average relative humidity 43.55%. The maximum indoor temperature was 24.4 °C and was registered at 12:00 by the Sensor 3 (located at the back rows). The minimum indoor temperature was 21.4 °C and was registered from 02:00 to 08:00 by the Sensor 2

Download English Version:

https://daneshyari.com/en/article/4764962

Download Persian Version:

https://daneshyari.com/article/4764962

Daneshyari.com