

## Accepted Manuscript


Adaptation of Thermal Power Plants: the (Ir)relevance of Climate (Change) Information

Christian W.J. Bogmans, Gerard P.J. Dijkema, Michelle T.H. van Vliet

PII: S0140-9883(16)30333-4  
DOI: doi: [10.1016/j.eneco.2016.11.012](https://doi.org/10.1016/j.eneco.2016.11.012)  
Reference: ENEECO 3495

To appear in: *Energy Economics*

Received date: 7 April 2015  
Revised date: 8 November 2016  
Accepted date: 17 November 2016



Please cite this article as: Bogmans, Christian W.J., Dijkema, Gerard P.J., van Vliet, Michelle T.H., Adaptation of Thermal Power Plants: the (Ir)relevance of Climate (Change) Information, *Energy Economics* (2016), doi: [10.1016/j.eneco.2016.11.012](https://doi.org/10.1016/j.eneco.2016.11.012)

This is a PDF file of an unedited manuscript that has been accepted for publication. As a service to our customers we are providing this early version of the manuscript. The manuscript will undergo copyediting, typesetting, and review of the resulting proof before it is published in its final form. Please note that during the production process errors may be discovered which could affect the content, and all legal disclaimers that apply to the journal pertain.

# Adaptation of Thermal Power Plants: the (Ir)relevance of Climate (Change) Information.<sup>☆</sup>

Christian W.J. Bogmans<sup>1,\*</sup>, Gerard P.J. Dijkema<sup>b,\*</sup>, Michelle T.H. van Vliet<sup>c,d</sup>

<sup>a</sup>Research Department, International Monetary Fund, Washington DC, the United States.

<sup>b</sup>Energy and Sustainability Research Institute Groningen, University of Groningen, the Netherlands.

<sup>c</sup>Water Systems and Global Change group, Wageningen University, the Netherlands.

<sup>d</sup>International Institute for Applied Systems Analysis, Laxenburg, Austria.

---

## Abstract

When does climate change information lead to adaptation? We analyze thermal power plant adaptation by means of investing in water-saving (cooling) technology to prevent a decrease in plant efficiency and load reduction. A comprehensive power plant investment model, forced with downscaled climate and hydrological projections, is then numerically solved to analyze the adaptation decisions of a selection of real power plants. We find that operators that base their decisions on current climatic conditions are likely to make identical choices and perform just as well as operators that are fully 'informed' about climate change. Where electricity supply is mainly generated by thermal power plants, heat waves, droughts and low river flow may impact electricity supply for decades to come.

*Keywords:* Thermal Power Plants, Climate Change, Adaptation, Real Options

*JEL:* D8, Q40, Q51, Q53, Q54

---

## 1. Introduction

### 1.1. Problem and question

In the United States more than 85% of all electricity is generated from nuclear and fossil fuels (e.g., coal, natural gas) in thermal power plants (EIA, 2015). At 75%, the European Union exhibits a significant dependence on this type of electricity production too (Eurostat, 2013). Many thermal power plants depend on a river for their cooling water. As such, these plants may experience forced load reductions or shut downs during heat waves or droughts. This is due to sheer lack of water, or due to environmental regulations that limit waste-heat discharges from power plants to prevent excessive river warming. The effects of two European heat waves in 2003 and 2006, during which several power plants in France and Germany were forced to reduce production or even had to shut down temporarily, have been well documented (see Kopytko and Perkins (2011), Rubbelke and Vogeles (2011) and Pechan and Eisenack (2014)). Cooling water is indeed "a critical resource in the thermoelectric power industry" (Feeley III et al., 2008).

No matter the extent and speed of mitigation, some degree of climate change over the course of this century seems inevitable (IPCC, 2014). Melting of glaciers will impact river runoff worldwide (IPCC, 2014), shifting rivers to become dominantly precipitation-fed. Secure cooling water supply, the life-line for thermal power plants, may no longer be a given. Indeed, van Vliet et al. (2012b) have shown that increases in river water temperature and decreases in summer river flow in Europe and the United States are to be expected, and subsequently find that in these regions the probability of extreme

---

\*Corresponding Author

Email addresses: cbogmans@imf.org (Christian W.J. Bogmans), g.p.j.dijkema@rug.nl (Gerard P.J. Dijkema)

Download English Version:

<https://daneshyari.com/en/article/5063786>

Download Persian Version:

<https://daneshyari.com/article/5063786>

[Daneshyari.com](https://daneshyari.com)