



# Reliability assessment for components of large scale photovoltaic systems



Amir Ahadi<sup>a,\*</sup>, Noradin Ghadimi<sup>a</sup>, Davar Mirabbasi<sup>b</sup>

<sup>a</sup> Young Researchers Club, Ardabil Branch, Islamic Azad University, Ardabil, Iran

<sup>b</sup> Department of Electrical Engineering, Ardabil Branch, Islamic Azad University, Ardabil, Iran

## HIGHLIGHTS

- This paper presents a complete and real structure of the large-scale PV systems.
- FTA is used to analyze the effects of a battery system on the system reliability.
- We estimate total component reliability and overall reliability for the PV system.
- Increasing nominal power output of the PV system will decrease Reliability.
- The critical components with priority for the PV system are revealed.

## ARTICLE INFO

### Article history:

Received 23 September 2013

Received in revised form

15 March 2014

Accepted 11 April 2014

Available online 26 April 2014

### Keywords:

Reliability assessment

Photovoltaic

Fault tree method

Analytical models

## ABSTRACT

Photovoltaic (PV) systems have significantly shifted from independent power generation systems to a large-scale grid-connected generation systems in recent years. The power output of PV systems is affected by the reliability of various components in the system. This study proposes an analytical approach to evaluate the reliability of large-scale, grid-connected PV systems.

The fault tree method with an exponential probability distribution function is used to analyze the components of large-scale PV systems. The system is considered in the various sequential and parallel fault combinations in order to find all realistic ways in which the top or undesired events can occur. Additionally, it can identify areas that the planned maintenance should focus on. By monitoring the critical components of a PV system, it is possible not only to improve the reliability of the system, but also to optimize the maintenance costs. The latter is achieved by informing the operators about the system component's status. This approach can be used to ensure secure operation of the system by its flexibility in monitoring system applications. The implementation demonstrates that the proposed method is effective and efficient and can conveniently incorporate more system maintenance plans and diagnostic strategies.

© 2014 Elsevier B.V. All rights reserved.

## 1. Introduction

Analyzing the reliability of PV power systems is important for planning and long-term operation, because the analysis helps predict system behavior over time and devise appropriately timed maintenance plans. It is a significant factor for the operator to be able to assess system reliability under long-term operations in

order to optimize decisions in design, engineering, procurement, construction, and service [1].

PV and wind systems produce electric power, which involves zero greenhouse gas emissions and fossil fuel consumption. The total capacity of grid-connected PV power systems has grown exponentially, from 300 MW in 2000 to approximately 67 GW in 2011 [2]. PV power generation will become the main focus of future energy development. As a clean energy, its application has gradually changed toward large-scale, grid-connected systems. It significantly influences the reliability, economics and operational stability of such systems [3]. The largest PV system with a generation capacity of 80 MW was installed in Sarnia, Ontario, Canada, in 2010 [4]. Additionally, the European PV Technology Platform Group

\* Corresponding author.

E-mail addresses: [amirahadi8@gmail.com](mailto:amirahadi8@gmail.com) (A. Ahadi), [noradin.ghadimi@gmail.com](mailto:noradin.ghadimi@gmail.com) (N. Ghadimi), [dmirabbasi@yahoo.com](mailto:dmirabbasi@yahoo.com) (D. Mirabbasi).

## Nomenclature

$I_{ph}$	internal equivalent current source	$I_s$	reverse saturation current
$V_t$	thermal voltage of the array	$N_s$	cells connected in series
$q$	the electron charge of $1.602 \times 10^{-19}$ Coulomb	$k$	the Boltzmann constant of $1.38 \times 10^{-23}$ J K <sup>-1</sup>
$T_j$	the temperature of the pn junction	$a$	the permittivity of the diode
$G$	solar irradiation	$K_i$	temperature coefficient (mA °C <sup>-1</sup> )
$\Delta T$	temperature deviation from the reference value	$G_n$	the reference irradiation
$T_n$	reference temperature	$E_g$	bandgap energy of the semiconductor
$I_{sr}$	the reference reverse saturation current	$P_{max}$	maximum output power of a PV cell
MPP	maximum power point	$V_{mpp,min}$	minimum MPP voltage of the inverter
$I_{SC}$	PV short-circuit current	$V_{mpp}$	PV voltage at the maximum power point
$V_{mpp,max}$	maximum MPP voltage of the inverter	$V_{oc}$	PV open-circuit voltage
$\mu_i$	PV temperature coefficient of $I_{SC}$	$\mu_v$	PV temperature coefficient of $V_{oc}$
$I_{mpp}$	PV current at the maximum power point	$V_{max}$	maximum operating voltage of the inverter
$I_{DC,max}$	maximum input DC current of the inverter	$R(t)$	reliability probability function
$F(t)$	failure probability function	$f(t)$	probability density function
ACS, DCS	AC or DC switch	GP	grid protection
CB	AC circuit breaker	SPD	surge protection device
INV	inverter	BD	blocking diode
CON	connector	PV	photovoltaic cell
CC	charge controller	BS	battery system
FV	Fussel–Vesely	DCB	differential circuit breaker
$Pr(E)$	failure probability	$1 - Pr(E)$	reliability probability
$P_{TOP}$	the probability of top event	$MCS_i$	minimal cut set i
$P_{MCS_i}$	the probability of occurrence of $MCS_i$	$m$	the number of basic events in the largest minimal cut set
$P_{B1}, P_{B2}, \dots, P_{Bn}$	the failure probabilities of basic events	$n$	the number of minimal cut sets
$M$	number of batteries in parallel	$N$	total number of batteries
$T$	the system's time to failure	$E_i$	the event that component $i$ operates without failure
$\lambda_{Battery}$	failure rate of the battery system	$\lambda_{Charge-Controller}$	failure rate of the charge controller

reports that PV systems are predicted to reach network parity in most of Europe in 2019 [5].

In recent literature, evaluating the reliability of solar PV has been a point of interest.

In Ref. [6], the investigators analyzed the reliability of solar PV power system designs using failure mode effect analysis (FMEA) and fault tree analysis (FTA), and also calculated the failure rates of the PV array and inverter. In Ref. [7], the investigators estimated reliability equations from the FTA but did not analyze the reliability probability functions. The maximum reliability of PV arrays with optimal interconnection of PV modules was investigated in Ref. [8–10]. In Ref. [11], the researchers evaluated the reliability of an electric power generation system, including a PV system, by considering the load under the assumption that none of the system components ever failed. The researchers in Ref. [12] proposed a new method for the calculation of the optimal configuration of large-scale PV systems. In Ref. [13], FTA and Markov chain method are jointly used to evaluate the behavior of PV system. The energy cost of PV system is estimated and applied to PV system designs. The investigators in Ref. [14] studied the reliability of battery voltage regulators (BVRs) used in PV systems and calculated the overall system reliability. In Ref. [15], the investigators proposed a model using Monte Carlo for the analysis of reliability of rechargeable batteries in photovoltaic power supply systems. In Ref. [16], the researchers discussed the PV inverters used in PV systems, presenting their experimental results. The reliability of PV systems was estimated in various small-scale field tests described in Refs. [17–19].

Although a wide variety of studies have been conducted about the large-scale, grid-connected PV systems [20–27], the real

electrical architecture of modern large-scale, grid-connected PV systems with battery backup requires further consideration.

This paper presents a technique for analyzing the reliability of large-scale, grid-connected PV systems using an exponential distribution based on FTA method and considering the presence of a battery system and charge controller. It is necessary to point out that changing the function from exponential distribution to, for example, accelerated life tests (ALTs) with Log-normal, Weibull or mixed-Weibull distributions did not alter the output of the proposed method. In addition, if the repair interval of the system components is sufficiently less than a critical value and does not influence the system operation, then the repair time could be ignored. Thus, in this study, it was assumed that any failures could not be repaired [7], [11], and [28–32]; therefore, if a component failed, the overall PV system was assumed to be in failure mode and the repair is finished during a short time. However, the overall system remaining in operation during that time, because the electric power of distribution system is sufficient for loads to use. It is also important to point out that in order to define the critical components, the scope of this paper is focused on the reliability evaluation of PV systems based on unrepairable components. It is assumed the repair time of the system failure is too short and the loads could be incorporated with the distribution system during failure. However, the proposed method is applicable when the repair and the common-cause degradation are considered.

The remainder of the paper is organized as follows. Section 2 describes the electrical structure of large-scale grid connected PV systems. Section 3 proposes the reliability modeling formulation. The case studies are presented in Section 4. Finally, the conclusions are provided in Section 5.

Download English Version:

<https://daneshyari.com/en/article/1284116>

Download Persian Version:

<https://daneshyari.com/article/1284116>

[Daneshyari.com](https://daneshyari.com)