



## Research Paper

# Entransy dissipation based optimization of a large-scale dry cooling system



Huimin Wei<sup>a</sup>, Xiaoze Du<sup>a,b,\*</sup>, Lijun Yang<sup>a</sup>, Yongping Yang<sup>a</sup>

<sup>a</sup> Key Laboratory of Condition Monitoring and Control for Power Plant Equipment (North China Electric Power University), Ministry of Education, Beijing 102206, China

<sup>b</sup> School of Energy and Power Engineering, Lanzhou University of Technology, Lanzhou 730050, China

## HIGHLIGHTS

- Correlation between tower loss and geometric parameters of dry cooling tower is investigated.
- Entransy dissipation is applied to dry cooling system as constraints of optimization.
- The minimization of annual cost is taken as the optimal objective with Lagrange multiplier method.
- Total annual cost of dry cooling system can be deduced significantly by optimization.

## ARTICLE INFO

### Article history:

Received 9 February 2017

Revised 14 June 2017

Accepted 22 June 2017

Available online 24 June 2017

### Keywords:

Large-scale dry cooling tower

System optimization

Entransy dissipation

Annual cost

## ABSTRACT

The natural draft dry cooling tower (NDDCT) with heat exchangers accounts for about 10 percent of the total investment of a power plant, so it is meaningful to optimize the geometric parameters to explore the potential that matching the cooling load of a power generating unit in the most cost effective way. The entransy dissipation equations of two typical irreversible heat transfer processes, including that the ambient air heated by heat exchangers and circulating water heated by the exhausted steam of turbine, are derived in this paper. Combined with the force balance equation of NDDCT, all parameters that may affect the performance and annual cost of a cooling system are taken into consideration. Such constituted constraints are applied to the Lagrange multiplier optimization of such a system. Based on the mathematical relation and conditional extremum method, an optimization equation group aiming to obtain the minimum of total annual cost is constructed. Finally, a practical 600 MW power generating unit is taken as an example to illustrate the applications of entransy dissipation based optimization principle. The result indicates that total annual cost of the dry cooling system can drop from \$6 420 643 to \$5 665 660.

© 2017 Elsevier Ltd. All rights reserved.

## 1. Introduction

Dry cooling that depends on natural convection and uses air as the cooling medium is preferable under certain conditions, especially for the insufficient water supplies in arid areas [1]. The high capital and operating costs of cooling system make it necessary to optimize the cost-performance trade-off.

Natural draft dry cooling tower (NDDCT) plays the most important role in the indirect dry cooling system. Since airflow in dry cooling systems is accomplished by natural draft, numerous investigations have concentrated on the influences of geometric parameters of (NDDCT) [2–5]. Huang et al. [2] investigated the cooling

performance of NDDCT with variations of geometric parameters via theoretical prediction and experiments. Du Preez et al. [3] made use of scale model tests to study the flow characteristics inside NDDCT and regarded the overall loss dependent on structure. The 17th IAHR international conference on cooling tower [4] gave a brief review of the latest developments in cooling technologies, including the influence of geometric parameters. Jacques du Plessis [5] conducted experimental work and CFD models to develop novel collection trough and basin system design, and empirical loss coefficient relations were presented and discussed.

A larger tower brings more cooling air passing through the heat exchangers and improves the cooling performance with an increasing investment cost yet. Hence the optimal objective is to match the cooling load of a power plant in the most cost effective way. Some researchers have addressed this kind of problem with a detail economic analysis [6–12]. Cui et al. [6] gave a concrete analysis on the relation of total annual cost and different combination

\* Corresponding author at: Key Laboratory of Condition Monitoring and Control for Power Plant Equipment (North China Electric Power University), Ministry of Education, Beijing 102206, China.

E-mail address: [duxz@ncepu.edu.cn](mailto:duxz@ncepu.edu.cn) (X. Du).



Download English Version:

<https://daneshyari.com/en/article/4991182>

Download Persian Version:

<https://daneshyari.com/article/4991182>

[Daneshyari.com](https://daneshyari.com)