



XVIII International Conference on Water Distribution Systems Analysis, WDSA2016

## Selection of Pumps as Turbines Substituting Pressure Reducing Valves

Gustavo Meirelles Lima<sup>a\*</sup>, Edevar Luvizotto Junior<sup>b</sup>, Bruno Melo Brentan<sup>c</sup>

<sup>a</sup>University of Campinas, Albert Einstein Avenue, 951, Campinas/SP, Brazil

<sup>b</sup>University of Campinas, Albert Einstein Avenue, 951, Campinas/SP, Brazil

<sup>c</sup>University of Campinas, Albert Einstein Avenue, 951, Campinas/SP, Brazil

---

### Abstract

Technical standards define operational limits for hydraulic parameters such as velocity or pressure. On this way, pressure control is a fundamental component for safe operation at water supply systems, mainly to reduce leakage, risk of disruptions and maintenance costs. The system topology and topography can define some high pressure zones and in this case the use of Pressure Reducing Valves - PRV - to maintain standards pressures on the sector is common. However, all the energy available on the fluid is dissipated through headloss. A turbine could be used instead of the PRV to produce electrical energy and to control pressure. In general, the power available in these sites is under 100 kW, so the use of Pumps as Turbines - PAT - is recommended to reduce the investment. Due of the dynamic operation through a day, the PAT will operate under different conditions of flow and head. This variation will affect its efficiency and head loss, which difficult the selection through conventional methods. Therefore, this paper proposes a method for PAT selection to operate instead a PRV. The method is based in the maximization of the energy produced, constrained to the pressure limits on each node of the network. To solve this problem, the optimization technique PSO is used and the available curves in literature, on the Suter plane, are used to simulate the PAT. The method is applied on a network and the results are compared with the PRV operation.

© 2016 The Authors. Published by Elsevier Ltd. This is an open access article under the CC BY-NC-ND license (<http://creativecommons.org/licenses/by-nc-nd/4.0/>).

Peer-review under responsibility of the organizing committee of the XVIII International Conference on Water Distribution Systems

*Keywords:* Pumps as Turbines; Optimization; PSO

---

\* Corresponding author. Tel.: +55 19 98456-3199.  
E-mail address: [limameirelles@gmail.com](mailto:limameirelles@gmail.com)

## 1. Introduction

Rational use of natural resources is increasingly important, not only for economical issues, but mainly for environmental reasons. The good operation of a water supply system is crucial for the sustainable development of a city, since they are large consumers of their water and energy resources. Climatic, social and political factors influence the consumption, and consequently the operation of a water supply system. In this context, the concept of Smart Networks arises, ensuring high quality service to inhabitants [1]. Field measurements creating a database and mathematical modeling allow decisions to be made quickly, supplying the consumer through an optimized operation, in line with the economic and environmental aspects mentioned.

Pressure control is one of the most important issues for optimized operation of networks. It is an important task to reduce the leakage volume and avoid the disruption of pipelines. The topography and topology of the system define high and low pressure zones. Technical standards establish the maximum and minimum values accepted for operation. In Brazil, ABNT through NBR12218 [2] sets the pressure in a supply network between 10 m (dynamic pressure) and 50 m (static pressure). In the low pressure areas, boosters with frequency inverters can be installed to maintain proper pressure on the network. For high-pressure zones, it is common use Pressure Reducing Valves - PRV, to maintain a sufficient pressure in the entrance sector, keeping the critical node with the desired minimum pressure.

However, from the energy view point, PRV dissipate pressure energy adding a localized head loss to the system. This energy loss opposes modern principles of rational use of resources. From this new paradigm, energy pressure could be used to actuate a turbine coupled to a generator, producing electricity and keeping the pressure reduction commitment in the sector. Due to the low power found at these sites, the use of conventional turbines is not feasible. An alternative is to use Pumps as Turbines - PAT, which have low cost and good efficiency. [3] show a similar behavior between PAT and PRV, indicating the viability in using this solution. However, [4-5], carried out simulations in extensive period and observed that during periods of low consumption, PAT is not able to insert a sufficient head loss to reduce pressure to acceptable standards. [6] find similar response of a PAT and PRV in a system in Iran, where the demand change throughout the day is not very significant. [7] propose as alternatives to improve the pressure control use variable speed PAT or add a PRV in parallel, while [8] suggest the use of multiples PAT in parallel in order to operate in different arrangements, according to the variations of daily consumption.

Despite the obvious advantages of using PAT, the selection of the machine for this purpose is complex. Traditional methods such as those proposed by [9-12] are valid only for the pump best efficiency point (BEP). Without its characteristic curve (head x flow) it is not possible evaluate the benefits in a network, since there is a wide range of available head according to the consumption. Furthermore, the PAT operation must seek not only energy production, but also the pressure control.

In this context, this paper proposes a method for PAT selection operating in water supply networks. The method is based on maximizing the benefit represented by the produced energy and the leakage volume reduced. As operating constraint, the method requires that the PAT should be able to keep the pressure on each node of the network within the established limits. The Best Efficiency Point - BEP - of the machine is set through an optimization process based on particle swarm (PSO). From these values, the specific speed of the machine is obtained selecting the nearest curve. For this, a set of complete characteristic curves of pumps available in the literature [13] and represented in Suter plan is used. In the final stage, the network is simulated with the selected machine to calculate the energy produced and the nodes pressures. The method was applied to a fictitious network, available in [14], and the results were compared with the PRV operation.

## 2. Pumps as Turbines Modeling

The characterization of hydraulic machines is made through curves relating head, flow, torque and speed. The alternation of the signs of these parameters define eight distinct operation areas, which can be represented by Suter plan [15]. Figure 1 shows an example of the 14 curves available in the work of [13]. The red part of the curves shows the operating zone as turbine. For each of the available curves, this operation area was identified, and considering speed as the nominal, new curves relating the dimensionless coefficients of flow,  $q$ , and head,  $h$ , were obtained, as shown in Figure 2. This new representation allowed the adjustment of a power curve (Eq. 1). Therefore,

Download English Version:

<https://daneshyari.com/en/article/5028267>

Download Persian Version:

<https://daneshyari.com/article/5028267>

[Daneshyari.com](https://daneshyari.com)