


Accepted Manuscript

Co-optimized Trading of Wind-Thermal-Pumped Storage System in Energy and Regulation Markets

Mustafa S. Al-Swaiti, Ali T. Al-Awami, Mohammad Waqas Khalid



PII: S0360-5442(17)31279-3
DOI: 10.1016/j.energy.2017.07.101
Reference: EGY 11289
To appear in: *Energy*
Received Date: 18 November 2016
Revised Date: 12 July 2017
Accepted Date: 14 July 2017

Please cite this article as: Mustafa S. Al-Swaiti, Ali T. Al-Awami, Mohammad Waqas Khalid, Co-optimized Trading of Wind-Thermal-Pumped Storage System in Energy and Regulation Markets, *Energy* (2017), doi: 10.1016/j.energy.2017.07.101

This is a PDF file of an unedited manuscript that has been accepted for publication. As a service to our customers we are providing this early version of the manuscript. The manuscript will undergo copyediting, typesetting, and review of the resulting proof before it is published in its final form. Please note that during the production process errors may be discovered which could affect the content, and all legal disclaimers that apply to the journal pertain.

Co-optimized Trading of Wind-Thermal-Pumped Storage System in Energy and Regulation Markets

Mustafa S. Al-Swaiti^a, Ali T. Al-Awami^b, and Mohammad Waqas Khalid^c,

^{a, b, c}Department of Electrical Engineering, King Fahd university of Petroleum & minerals, Dhahran
31261, Saudi Arabia

^a mwaiti@kfupm.edu.sa

^b aliawami@kfupm.edu.sa (corresponding author)

Abstract— Trading of wind energy in day-ahead electricity markets entails significant risks. Wind traders are, therefore, interested in mitigating their trading risks in a number of ways. This work suggests addressing this issue in a comprehensive manner by coordinating the trading of wind resources with thermal resources and a pumped-hydro storage system (PHS) and co-optimizing the trading in energy and regulation markets. The trading strategy is modeled as a mixed integer linear stochastic program that takes into account several uncertain parameters, including wind power outputs, prices for energy, balancing, and regulation, and regulation deployments. In this optimization, the trader's attitude toward risks is controlled by using the metric of conditional value at risk (CVaR). Simulation results show that coordinated and co-optimized trading of the generation resources and PHS significantly improve the total expected profits and mitigates trader's risks.

Index Terms— Pumped-hydro storage system (PHS), wind-thermal generation, coordination, Risk, Regulation market, mixed integer linear program, stochastic programming.

NOMENCLATURE

The notations used through the paper are stated below:

A. Indices:

t	Bidding period
s	Scenario
g	Thermal unit
n	PHS unit
d	Wind plant
e	Segment

B. Decision variables:

P_t, P_w, P_h	Optimal bid of thermal/wind/PHS unit
P_{ac}	Total actual thermal power output
P_{acm}	Actual thermal power output to the market
P_{acp}	Actual thermal power output to PHS
W_{acm}	Actual wind power output to the market
W_{acp}	Actual wind power output to PHS
H^{ac}	Actual power output from PHS unit
M	Optimal offer from PHS to purchase energy from the market

Download English Version:

<https://daneshyari.com/en/article/5475554>

Download Persian Version:

<https://daneshyari.com/article/5475554>

[Daneshyari.com](https://daneshyari.com)