


Accepted Manuscript

Optimization of Ultrasonic Waves Application in Municipal Wastewater Sludge Treatment Using Response Surface Method

Mahdi Ghafarzadeh, Rezvan Abedini, Rohollah Rajabi



PII: S0959-6526(17)30385-2

DOI: 10.1016/j.jclepro.2017.02.159

Reference: JCLP 9085

To appear in: *Journal of Cleaner Production*

Received Date: 07 May 2016

Revised Date: 09 January 2017

Accepted Date: 22 February 2017

Please cite this article as: Mahdi Ghafarzadeh, Rezvan Abedini, Rohollah Rajabi, Optimization of Ultrasonic Waves Application in Municipal Wastewater Sludge Treatment Using Response Surface Method, *Journal of Cleaner Production* (2017), doi: 10.1016/j.jclepro.2017.02.159

This is a PDF file of an unedited manuscript that has been accepted for publication. As a service to our customers we are providing this early version of the manuscript. The manuscript will undergo copyediting, typesetting, and review of the resulting proof before it is published in its final form. Please note that during the production process errors may be discovered which could affect the content, and all legal disclaimers that apply to the journal pertain.

Optimization of Ultrasonic Waves Application in Municipal Wastewater Sludge Treatment Using Response Surface Method

Mahdi Ghafarzadeh¹, Rezvan Abedini^{*2}, Rohollah Rajabi³

1- Sharif University of Technology, Tehran, Iran, ghafarзад_mahdi@sharif.edu

2- Amirkabir University of Technology, Tehran, Iran, rezvanabedini@aut.ac.ir

3- K. N. Toosi University of Technology, Tehran, Iran, rrajabi60@gmail.com

Abstract

Today, many limitations are faced in sludge treatment and disposal. Therefore evaluation of different approaches to reduce sludge production in the activated sludge process has attracted great attention. Application of ultrasonic waves in sludge treatment caused to reduce sludge volume and accelerate sludge digestion. This research intended to study the efficiency of ultrasound in dewatering biological sludge in wastewater treatment plants under different conditions. In this study, response surface method was used to investigate results and optimum conditions were determined. Sludge was treated in different conditions as follows: 330 to 920 watts ultrasound power, 1.5 to 3.9 liters sample volume and 6 to 20 minutes ultrasonic exposure duration. Then, the effect of waves was studied in terms of SRF (specific resistance to filtration). Results of the experiments showed that, the ultrasonic method significantly increases the SRF. Also based on response surface method, the best performance of ultrasonic application in sludge treatment is achievable at the following conditions: 625 watts ultrasound power, 2.7 liters sample volume and 13 minutes ultrasonic exposure duration. A mathematical model for accurate prediction of SRF changes of the sludge was derived using statistical data.

Keyword: Sludge Treatment, Response Surface Method, Ultrasonic.

Download English Version:

<https://daneshyari.com/en/article/5480597>

Download Persian Version:

<https://daneshyari.com/article/5480597>

[Daneshyari.com](https://daneshyari.com)