

Accepted Manuscript

Title: Online Adaptive Dynamic Programming Based on Echo State Networks for Dissolved Oxygen Control

Author: Bo Ying-Chun


PII: S1568-4946(17)30554-9
DOI: <http://dx.doi.org/10.1016/j.asoc.2017.09.015>
Reference: ASOC 4462

To appear in: *Applied Soft Computing*

Received date: 10-8-2016
Revised date: 3-9-2017
Accepted date: 5-9-2017

Please cite this article as: Ying-Chun Bo, Online Adaptive Dynamic Programming Based on Echo State Networks for Dissolved Oxygen Control, *Applied Soft Computing Journal* <http://dx.doi.org/10.1016/j.asoc.2017.09.015>

This is a PDF file of an unedited manuscript that has been accepted for publication. As a service to our customers we are providing this early version of the manuscript. The manuscript will undergo copyediting, typesetting, and review of the resulting proof before it is published in its final form. Please note that during the production process errors may be discovered which could affect the content, and all legal disclaimers that apply to the journal pertain.




Online Adaptive Dynamic Programming Based on Echo State Networks for Dissolved Oxygen Control

BO Ying-Chun

College of Information and Control Engineering, China University of Petroleum, Qingdao, China, 266580, Email, boyingchun@sina.com.cn.

Graphical abstract



The highlights of this paper are as follows:

- Echo state networks are induced into ADP scheme, and it can solve the local minimum problem widely existed in ADP with traditional artificial neural networks.
- an online learning algorithm for ESN-based ADP controller is proposed, and its convergence is investigated systematically.
- the proposed ESN-based ADP controller is tested and evaluated on BSM1—a wastewater treatment plant for controlling the dissolved oxygen level, and it achieves a better performance than other controllers.

Abstract: To solve the control problem of dissolved oxygen concentration in wastewater treatment process (WWTP), an online adaptive dynamic programming (ADP) scheme based on echo state networks (ESN) is proposed. The ESN-based ADP controller contains three modules composed of echo state networks, and the three modules approximate respectively the critic index, the system model and the optimal control policy. Further, an online learning algorithm on the basis of recursive least squares (RLS) is designed to train the ESN-based ADP controller, and also the convergence of the online learning algorithm is investigated. The design and operation of the ESN-based ADP controller depend mainly on the online data observed from controlled system, and minor prior knowledge is required. The proposed ESN-based ADP controller's performance is tested and evaluated on Benchmark Simulation Model no. 1 (BSM1)—a general WWTP benchmark. Experimental results demonstrate that the proposed controller can achieve high performance on dissolved oxygen level control in WWTP.

Key words: adaptive dynamic programming; echo state network; online learning; dissolved oxygen; wastewater treatment

Download English Version:

<https://daneshyari.com/en/article/6904323>

Download Persian Version:

<https://daneshyari.com/article/6904323>

[Daneshyari.com](https://daneshyari.com)