

## Accepted Manuscript

Theoretical analysis of suitable fluids for high temperature heat pumps up to 125 °C heat delivery

Opeyemi Bamigbetan , Trygve M. Eikevik , Petter Neksa , Michael Bantle , Christian Schlemminger

PII: S0140-7007(18)30175-0  
DOI: [10.1016/j.ijrefrig.2018.05.017](https://doi.org/10.1016/j.ijrefrig.2018.05.017)  
Reference: IJIR 3985



To appear in: *International Journal of Refrigeration*

Received date: 22 September 2017  
Revised date: 10 May 2018  
Accepted date: 14 May 2018

Please cite this article as: Opeyemi Bamigbetan , Trygve M. Eikevik , Petter Neksa , Michael Bantle , Christian Schlemminger , Theoretical analysis of suitable fluids for high temperature heat pumps up to 125 °C heat delivery, *International Journal of Refrigeration* (2018), doi: [10.1016/j.ijrefrig.2018.05.017](https://doi.org/10.1016/j.ijrefrig.2018.05.017)

This is a PDF file of an unedited manuscript that has been accepted for publication. As a service to our customers we are providing this early version of the manuscript. The manuscript will undergo copyediting, typesetting, and review of the resulting proof before it is published in its final form. Please note that during the production process errors may be discovered which could affect the content, and all legal disclaimers that apply to the journal pertain.

## Highlights

- Suitable working fluids for high temperature heat pumping up to 125 °C are evaluated
- Technological, safety and environmental limitations constrain working fluid selection
- The operating parameters and performance of each fluid are compared
- R600 was found to have the highest performance and flexibility for the considered conditions

ACCEPTED MANUSCRIPT

Download English Version:

<https://daneshyari.com/en/article/7175212>

Download Persian Version:

<https://daneshyari.com/article/7175212>

[Daneshyari.com](https://daneshyari.com)