


Accepted Manuscript

Hybrid renewable energy systems for renewable integration in microgrids:
influence of sizing on performance

Bartolucci Lorenzo, Cordiner Stefano, Mulone Vincenzo, Rocco Vittorio, Rossi
Joao Luis



PII: S0360-5442(18)30574-7
DOI: 10.1016/j.energy.2018.03.165
Reference: EGY 12623
To appear in: *Energy*
Received Date: 26 December 2017
Revised Date: 28 March 2018
Accepted Date: 29 March 2018

Please cite this article as: Bartolucci Lorenzo, Cordiner Stefano, Mulone Vincenzo, Rocco Vittorio, Rossi Joao Luis, Hybrid renewable energy systems for renewable integration in microgrids: influence of sizing on performance, *Energy* (2018), doi: 10.1016/j.energy.2018.03.165

This is a PDF file of an unedited manuscript that has been accepted for publication. As a service to our customers we are providing this early version of the manuscript. The manuscript will undergo copyediting, typesetting, and review of the resulting proof before it is published in its final form. Please note that during the production process errors may be discovered which could affect the content, and all legal disclaimers that apply to the journal pertain.

HYBRID RENEWABLE ENERGY SYSTEMS FOR RENEWABLE INTEGRATION IN MICROGRIDS: INFLUENCE OF SIZING ON PERFORMANCE

Bartolucci Lorenzo^a, Cordiner Stefano^a, Mulone Vincenzo^a, Rocco Vittorio^a and Rossi Joao Luis^a.

^aUniversity of Rome Tor Vergata, via del Politecnico 1, 00133 Rome, Italy

CORRESPONDENCE ADDRESSES: Bartolucci Lorenzo, Ph.D., University of Rome Tor Vergata, Department of Industrial Engineering, via del Politecnico 1, 00133 Rome, Italy, e-mail: lorenzo.bartolucci@uniroma2.it

Abstract

Hybrid Power System (HPS) are effective means for the increase of the exploitation of local renewable energy sources in the Distributed Generation (DG) paradigm concept. This work aims at analyzing thoroughly the effects mentioned for two different energy demand profiles: an industrial facility and a residential complex of 75 apartments. A parametric analysis with different components sizing is proposed to evaluate the optimal solution in terms of deployment of renewable energies, resilience of the system and environmental impact, considering the economic convenience as a sustainability constraint. Results show that the two main drivers for the convenience of such systems are the load profile and the PV power plant power sizing. The former shows greater effectiveness of the microgrid management for the residential load rather than the industrial one. The latter shows that the correct sizing of the PV powerplant allows for a smarter use of the battery and gives lesser dependence on the energy exchanged with the grid.

Keywords: Renewables, Distributed generation, Fuel Cells, Microgrids, Hybrid Renewable Energy Systems.

Download English Version:

<https://daneshyari.com/en/article/8071722>

Download Persian Version:

<https://daneshyari.com/article/8071722>

[Daneshyari.com](https://daneshyari.com)