


Accepted Manuscript

Analysis of Oil-free Linear Compressor Operated at High Pressure Ratios for Household Refrigeration

Kun Liang



PII: S0360-5442(18)30477-8
DOI: 10.1016/j.energy.2018.03.068
Reference: EGY 12526
To appear in: *Energy*
Received Date: 18 November 2017
Revised Date: 18 February 2018
Accepted Date: 12 March 2018

Please cite this article as: Kun Liang, Analysis of Oil-free Linear Compressor Operated at High Pressure Ratios for Household Refrigeration, *Energy* (2018), doi: 10.1016/j.energy.2018.03.068

This is a PDF file of an unedited manuscript that has been accepted for publication. As a service to our customers we are providing this early version of the manuscript. The manuscript will undergo copyediting, typesetting, and review of the resulting proof before it is published in its final form. Please note that during the production process errors may be discovered which could affect the content, and all legal disclaimers that apply to the journal pertain.

Analysis of Oil-free Linear Compressor Operated at High Pressure Ratios for Household Refrigeration

Kun Liang

Department of Engineering and Design, University of Sussex, Brighton BN1 9QT, UK

Tel: +44 1273 678573. Email address: kun.liang@sussex.ac.uk

Abstract

Compared with conventional reciprocating compressor for vapour compression refrigeration (VCR) system, linear compressor offers higher energy efficiency and oil-free operation, which allows the use of mini/micro-channel heat exchangers. However, there are key challenges when oil-free linear compressors are used for household refrigeration with typical high pressure ratios (above 10), such as high clearance loss, high piston offset, and very non-linear gas spring. Previous papers by the author have demonstrated the feasibility of oil-free linear compressor for electronics cooling at lower pressure ratios (below 3.5). This paper presented comprehensive analysis of these issues as a key step towards developing oil-free linear compressor for household refrigeration. The model of non-linear gas spring at high pressure ratios is validated by measurements of a previous prototype linear compressor with minimum flow. Piston offset can be effectively controlled by solenoid valve at 1 Hz. Gas leakage increases by a factor of 2.5 if the piston is fully eccentric in the cylinder. The gas leakage loss can be 27% of power input for pressure ratio of 13.6 using R600a.

Keywords: linear compressor, household refrigeration, resonant frequency, gas spring, gas leakage, high pressure ratio

Download English Version:

<https://daneshyari.com/en/article/8071754>

Download Persian Version:

<https://daneshyari.com/article/8071754>

[Daneshyari.com](https://daneshyari.com)