


Accepted Manuscript

Mutual information for Evaluating Renewable Power Penetration Impacts in a Distributed Generation System

Yu Luo, Yixiang Shi, Yi Zheng, Zhongxue Gang, Ningsheng Cai



PII: S0360-5442(17)31554-2
DOI: 10.1016/j.energy.2017.09.033
Reference: EGY 11527
To appear in: *Energy*
Received Date: 21 February 2017
Revised Date: 31 August 2017
Accepted Date: 08 September 2017

Please cite this article as: Yu Luo, Yixiang Shi, Yi Zheng, Zhongxue Gang, Ningsheng Cai, Mutual information for Evaluating Renewable Power Penetration Impacts in a Distributed Generation System, *Energy* (2017), doi: 10.1016/j.energy.2017.09.033

This is a PDF file of an unedited manuscript that has been accepted for publication. As a service to our customers we are providing this early version of the manuscript. The manuscript will undergo copyediting, typesetting, and review of the resulting proof before it is published in its final form. Please note that during the production process errors may be discovered which could affect the content, and all legal disclaimers that apply to the journal pertain.

1 **Mutual information for Evaluating Renewable Power**
2 **Penetration Impacts in a Distributed Generation System**

3 Yu Luo^a, Yixiang Shi^{* a}, Yi Zheng^a, Zhongxue Gang^b, Ningsheng Cai^a

4 a. Key Laboratory for Thermal Science and Power Engineering of Ministry of Education,
5 Department of Thermal Engineering, Tsinghua University, Beijing 100084, China

6 b. ENN Science & Technology Development Co., Ltd, Langfang 065001, Hebei Province, China
7

8 **ABSTRACT**

9 Renewable energy (RE) is regarded as the main part of the primary energy in the
10 forthcoming “energy internet”. However, the intermittence and variability of renewable
11 energy limit its present penetration. To study the effect of the renewable energy
12 penetration on power supply and demand, a dynamic distributed multi-energy
13 generation system combining RE, natural gas (NG) and energy storage was built based
14 on the semi-physical model library. The model library consisted of four key links of a
15 distributed generation system: a generation link, storage link, recycle link and user-load
16 link. Simulation indicated that the responses of a reversible solid oxide fuel cell (RSOC)
17 and Li-ion battery were faster than that of a gas internal combustion engine (GICE).
18 Furthermore, a novel indicator based on the mutual information was applied in a
19 distributed generation system coupling RE, NG and energy storage. The results showed
20 that the indicator was applicable for evaluating power balance degree and device
21 capacity selection. Based on the indicator, it was found that the power balance degree

* Corresponding author. Tel.: +86-10-62789955; Fax: +86-10-62789955.

Email: shyx@tsinghua.edu.cn.

Download English Version:

<https://daneshyari.com/en/article/8072613>

Download Persian Version:

<https://daneshyari.com/article/8072613>

[Daneshyari.com](https://daneshyari.com)