




Contents lists available at ScienceDirect

Energy

journal homepage: www.elsevier.com/locate/energy

Multi-objective probabilistic reactive power and voltage control with wind site correlations

Mohsen Zare^a, Taher Niknam^a, Rasoul Azizipanah-Abarghooee^a, Babak Amiri^{b,*}

^a Department of Electronic and Electrical Engineering, Shiraz University of Technology, Shiraz, Iran

^b Faculty of Engineering & IT, The University of Sydney, Sydney, Australia

ARTICLE INFO

Article history:

Received 8 July 2013

Received in revised form

24 December 2013

Accepted 9 January 2014

Available online xxx

Keywords:

Modified bee swarm optimization

Multi-objective optimization problem

Point estimated methods

Reactive power and voltage control

Wind site correlation

ABSTRACT

This paper proposes a multi-objective probabilistic reactive power and voltage control in distribution networks using wind turbines, hydro turbines, fuel cells, static compensators and load tap changing transforms. The objective functions are total electrical energy costs, the electrical energy losses, total emissions produced, and voltage deviations during the next day. Since the wind sources and load demand have intermittent characteristics, a probabilistic load flow based on $2m + 1$ point estimated method is used to investigate the objective functions. The correlation in wind speed is considered as the distances between WTs are not large in distribution systems. Furthermore, a multi-objective modified bee swarm optimization is proposed to solve the optimization problem by defining a set of non-dominated points as the solutions. A fuzzy based clustering is used to control the size of the repository and a niching method is utilized to choose the best solution during the optimization process. Performance of the proposed algorithm is tested on a 69-bus distribution feeder. The results confirm the necessity of modeling the reactive power and voltage control problem in a stochastic framework. Also, the effects of wind site correlations on different objective functions are discussed completely.

© 2014 Elsevier Ltd. All rights reserved.

1. Introduction

Reactive power and voltage control is one of the most important problems in power system from management or planning point of view [1]. It is usually addressed by minimizing the predefined objective functions while regulating the voltage over feeders and controlling reactive power (or power factor) at substations using transformer LTC (Load Tap Changers) and fixed and switched capacitor banks [2]. Besides, competition in open access market and public environmental concerns encourages the use of RESs (renewable energy sources) [3]. Integration of RESs in distribution systems posed many issues for the SOs due to their intermittent nature, reverse of power flow, small X/R ratio of distribution lines, and radial structure of networks [4,5]. These issues have increased with high proliferation of RESs.

Many researchers have investigated the RPVC (reactive power and voltage control) problem in the distribution networks. Baron et al. suggested a supervisory RPVC scheme based on the measurements, which were available at the substation [6]. Roytelman et al. proposed a centralized Volt/Var algorithm for the distribution

system management [7]. Niknam et al. suggested a cost-based compensation methodology for the daily RPVC in the presence of DG (Distributed Generation) units [8]. A combined heuristic and algorithmic approach for reactive power optimization with different load level in distribution systems was presented in Ref. [9]. Viawan and Karlsson investigated the impact of DG units on the voltage and reactive power control scheme. They also proposed a proper coordination method among DG units and other traditional voltage and reactive power control apparatus [10].

In above researches [6–10], the uncertainties imposed on distribution system are not considered. The uncertain variables in distribution networks are loads at consumer's terminal and wind speed for WTs. Liang et al. suggested a fuzzy optimization approach to solve the Volt/Var control problem in distribution systems [11]. In their proposed method, the errors in the forecast load demand and wind speed modeled by means of fuzzy sets. They used a max–min operator to solve the multi-objective problem. Hong and Luo proposed a method to regulate the voltage profile of the operation planning in the distribution networks [2]. They used a cumulant method to calculate the bus voltage fluctuation by using genetic algorithm. Also, several other articles have been investigated the uncertainty related to the DG units in distribution networks. El-Khattam et al. proposed a new algorithm in order to evaluate the distribution network performance with DG units considering the

* Corresponding author.

E-mail address: amiri.babak@sydney.edu.au (B. Amiri).

Nomenclature

Symbols

$C_{bmax(min)}$ maximum (minimum) values of the cognitive weight factors.
 $C_{gmax(min)}$ minimum (maximum) values of the social weight factors.
 $C_{u(o)}^t$ over (under) estimated cost coefficients
 $DOT_{icap}^{cap,max}$ maximum allowable number of switching of the i th capacitor.
 DOT_{itrn}^{trn} number of switching of the i th transformer taps.
 $DOT_{itrn}^{trn,max}$ maximum allowable number of changing of the i th transformer tap.
 $E(C^t)$ expected value for the electric energy supply costs by RES and distribution companies (\$).
 $E(L^t)$ expected value for the network losses (kWh).
 $E(E^t)$ expected value for the total emission of RES and grids (kg).
 $E(V_d^t)$ expected value for the voltage deviation from nominal (p.u).
 E_{RES}^t emission rate of RES i (kg/kWh).
 E_{grid}^t emission coefficient of energy supplied at the i th grid (kg/kWh).
 $\tilde{j}$ probabilistic Jacobian matrix
 h^t duration of time interval t (h).
 I_{ibr}^t current of branch i (A).
 $Iter(iter_{max})$ current (maximum) iteration.
 m number of input random variables.
 M^{iter} vector of mean for all control variables.
 $max(min)_{var}$ upper and lower limits of each control variable.
 n number of the decision variables.
 $N_{efb(ob, sb)}$ number of experienced forager (onlooker, scout) bees.
 N_{obj} number of objective functions
 N_{rep} number of non-dominated solutions in repository
 N_{RES} number of RES ($N_{WT} + N_{FC} + N_{HY}$).
 N_{ORV} number of output random variables.
 $N\mu$ normalized membership value
 $P(P')$ vector of input correlated(uncorrelated)variables.
 P_{RES} vector of RES active power output.
 P_{FC} vector of FC active power output.
 P_{iFC} vector of active power output for FC i .
 P_{iFC}^t active power output for FC i .
 P_{HY} vector of HY active power output.
 P_{iHY} vector of active power output for HY i .
 P_{iHY}^t active power output for HY i .
 $|p_{ij}^{br}|^t$ active power flow of line from bus i to bus j (kW).
 P_{igrid}^t active power withdrawal from the i th grid (kW).
 P_{iRES}^t active power output of RES i (kW).
 $P_{min(max), iRES}^t$ minimum (maximum) power output of the i th RES.
 $p_{ij}^{br,max}$ active power limit of line between bus i and j (kW).
 $P_{igrid}^{min(max)}$ minimum (maximum) power factor of the i th grid.
 Pf_{igrid}^t power factor of grid i .
 $P_{iRES}^{min(max)}$ minimum (maximum) power factor of the i th RES.
 Pf_{iRES}^t power factor of RES i .
 p_l input random variable l ($l = 1, 2, \dots, m$).

$Price_{grid}^t$ electrical energy price supplied by grid i (\$/kWh).
 $Price_{RES}^t$ electric energy price supplied by RES i (\$/kWh).
 $rand, r, r_b, r_g$ random number between 0 and 1.
 R_{ibr} resistance of branch i (Ω).
 R_factor constant value between 0 and 1.
 s constant value in the range [0, 10].
 T number of time intervals.
 Tap_{itrn} tap positions vector of transformer i .
 $Tap_{itrn}^{min(max)}$ minimum (maximum) tap position of the i th transformer.
 Tap_{itrn}^t tap position of transformer i .
 Tap_{itrn} transformer tap position matrix.
 TF random number equals 1 or 2.
 U_{cap} capacitor statuses (on/off) matrix.
 U_{icap} status vector of capacitor i .
 U_{icap}^t status (on/off) of capacitor i .
 $V_{i,min(max)}$ minimum (maximum) voltage magnitude of the i th bus (V).
 V_i^N nominal voltage of bus i (V).
 V_i^t voltage magnitude of bus i (V).
 X vector of control variables.
 $y_{min(max)}$ minimum (maximum) values of the sinusoidal function.
 Z vector of output variables.
 z_i output random variable i .
 $\xi_{l,k}$ standard location.
 $\mu_{p_l}(\sigma_{p_l})$ mean (standard deviation) of the input variable p_l .
 $\lambda_{p_l,3}$ third standard central moments of p_l (skewness)
 X vector of control variables.
 $y_{min(max)}$ minimum (maximum) values of the sinusoidal function.
 $\lambda_{p_l,4}$ fourth standard central moments of p_l (kurtosis)

Subscripts

br branch.
 cap capacitor.
 FC fuel-cell.
 $grid$ grid.
 HY hydro turbine.
 RES renewable energy source.
 trn transformer.
 WT wind turbine.
 ξ, β, χ experienced forager, onlooker, and scout bees.
 ψ mutated vector.

Subscripts

t t th time interval (corresponding to t th load level).

Abbreviation

BSO bee swarm optimization
 EA evolutionary algorithm
 EFB experienced forager bee
 FC fuel cell
 HY hydro turbine
 MBSO modified bee swarm optimization
 MPRPVC multiobjective probabilistic RPVC
 MRPVC multiobjective RPVC
 OB onlooker bee
 PDF probability distribution function
 PEM point estimated method
 PLF probabilistic load flow

Download English Version:

<https://daneshyari.com/en/article/8078576>

Download Persian Version:

<https://daneshyari.com/article/8078576>

[Daneshyari.com](https://daneshyari.com)